

SHEET NOTES

KEY NOTES

- 1 CONTRACTOR TO INSTALL NEW ROOFTOP UNIT PER SCHEDULE. INSTALL ON 14" CURB. EXTEND DUCTS DOWN THROUGH CURB AND CONTINUE AS SHOWN ON SHEETS M1.0 AND M3.0. COORDINATE WITH PLUMBING CONTRACTOR TO MAINTAIN 10 FEET CLEAR OF ANY PLUMBING VENTS.
- 2 CONTRACTOR TO PROVIDE EXHAUST FAN PER SCHEDULE. MOUNT ON 12" MINIMUM CURB. LOCATE MINIMUM 10 FEET FROM ANY OSA INTAKE.
- 3 CONTRACTOR TO MOUNT DUCTLESS AIR CONDITIONING CONDENSING UNIT ON 14" CURB. ROUTE LINE SET, POWER AND CONTROLS DOWN THROUGH PORTALS PLUS ROOF JACK OR APPROVED.


WILCO EUGENE

WILTH & WILLOW CREEK
EUGENE, OREGON 97402

WILCO

200 INDUSTRIAL WAY
MT. ANGEL, OR 97362

project number 18-25
date 10/03/22
revisions



HVAC ROOF PLAN

sheet number

M2.0

03/10/23

