

SHEET NOTES

CONTRACTOR TO LOCATE REMOTE SENSORS AS SHOWN, COORDINATE LOCATION WITH OWNER'S REPRESENTATIVE PRIOR TO ROUGH IN. LOCATE THERMOSTAT IN IT ROOM. LABEL EACH THERMOSTAT WITH UNIT AND LOCATION SERVED.

KEY NOTES

- CONTRACTOR TO PROVIDE NEW ROOF MOUNTED EXHAUST FAN FOR BATHING. PROVIDE MOTORIZED DAMPER IN 24x20" EXHAUST DUCT INTERLOCK WITH EXHAUST FAN OPERATION. FAN TO RUN DURING BUSINESS HOURS, CIRCUIT THROUGH WATTSTOPPER LP8 PEANUT PANEL OR APPROVED, CONNECT THROUGH HUMIDISTAT TO OVERRIDE FAN ON IF HUMIDITY IS DETECTED AFTER HOURS.
- CONTRACTOR TO INSTALL 4" DRYER DUCT UP THROUGH ROOF. INSTALL WITH INLINE FANTECH DBLT4W LINT TRAP OR APPROVED ALTERNATE. TERMINATE WITH CURB MOUNTED ROOF VENT WITH BACKDRAFT DAMPER.
- CONTRACTOR TO EXTEND 30x12" RETURN DUCT FROM RTU-5 TO SALES FLOOR, TERMINATE END OF RETURN DUCT AT A 45 DEGREE ANGLE FACING UP, COVER OPENING WITH 1" WIRE MESH SCREEN.
- CONTRACTOR TO EXTEND 12x12" EXHAUST DUCT UP THROUGH ROOF TO EF-2. ON ROOF, EXTEND EXHAUST DUCT TO EACH SPACE SHOWN, PROVIDE MANUAL VOLUME DAMPER ON EACH BRANCH, BALANCE AS SHOWN. COORDINATE WITH GENERAL CONTRACTOR TO PROVIDE UNDERCUT DOORS FOR TRANSFER AIR. EXHAUST FAN EF-2 TO OPERATE DURING BUSINESS HOURS, CIRCUIT THROUGH WATTSTOPPER LP8 PEANUT PANEL OR APPROVED.
- CONTRACTOR TO INSTALL DUCTLESS SPLIT SYSTEM UNIT PER SCHEDULE. COORDINATE CONDENSATE PUMP WITH ELECTRICIAN AND PLUMBER TO PROVIDE COMPLETE SYSTEM. ROUTE REFRIGERANT LINES, POWER AND CONTROLS UP THROUGH ROOF TO CONDENSING UNIT. REFER TO EQUIPMENT MANUFACTURER'S INSTALLATION INSTRUCTIONS FOR LINESET INSTALLATION.
- CONTRACTOR TO ROUTE 20x12" SUPPLY DUCT UP TO ROOFTOP UNIT, TRANSITION TO UNIT CONNECT. EXTEND 18x12" RETURN DUCT UP TO ROOFTOP UNIT, TRANSITION TO UNIT CONNECTION. PROVIDE DIFFUSERS AND GRILLES AS SHOWN. BALANCE AS SHOWN SET OUTSIDE AIR TO 100 CFM.
- CONTRACTOR TO ROUTE 20x12" SUPPLY DUCT UP TO ROOFTOP UNIT, TRANSITION TO UNIT CONNECT. EXTEND 20x12" RETURN DUCT UP TO ROOFTOP UNIT, TRANSITION TO UNIT CONNECTION. PROVIDE DIFFUSERS AND GRILLES AS SHOWN. BALANCE AS SHOWN SET OUTSIDE AIR TO 100 CFM.



03/10/23


WILCO EUGENE

WILLOW CREEK
EUGENE, OREGON 97402

WILCO

200 INDUSTRIAL WAY
MT. ANGEL, OR 97362

project number 18-25
date 10/03/22
revisions



ENLARGED
HVAC PLANS
sheet number

M3.0