



SIDEWALL FRAMING PLAN

GENERAL NOTES

1. STD. ROD/CABLE SIZES PER PART PREFIX ARE:
- | <u>ROD</u> | <u>CABLE</u> |
|--------------------|--------------------|
| RD05— = 5/8" ROD | CA02— = 1/4" CABLE |
| RD06— = 3/4" ROD | CA03— = 3/8" CABLE |
| RD07— = 7/8" ROD | CA04— = 1/2" CABLE |
| RD08— = 1" ROD | |
| RD09— = 1 1/8" ROD | |
| RD10— = 1 1/4" ROD | |
2. ROD/CABLE BRACING THAT OCCURS IN FLUSH OR INSET GIRT CONDITIONS WILL REQUIRE FIELD SLOTTING OF GIRT WEBS TO ALLOW FOR BRACING.
3. FRAMED OPENINGS WHICH ARE FIELD LOCATED WILL REQUIRE FIELD CUTTING OF GIRTS AND SHEETING.
4. THIS DRAWING IS NOT TO SCALE.

PROJECT NAME
WILCO HAY STORAGE - EUGENE
EUGENE, OR 97402

CUSTOMER NAME
WVALEN CONSTRUCTION, LLC
TUALATIN, OR 97062

REGISTERED PROFESSIONAL
ENGINEER
97085PE
01/31/2023
OREGON
MAR. 9 2023
WING HONG LO
EXPIRATION DATE: 12-31-2024

This seal pertains only to the materials designed and supplied by the Metal Building Manufacturer. The drawings and the metal buildings which they represent are the product of the Metal Building Manufacturer, the registered professional engineer whose seal appears on these drawings is employed by the Metal Building Manufacturer and does not serve as or represent the project engineer of record and shall not be construed as such.

E6 of 9

1

1